



NON-RIGID FIRE BARRIER SCHEME

Certificate number: IFCC 1461

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

TBA Protective Technologies Ltd

Unit 3 Transpennine Trading Estate
Gorrells Way, Rochdale,
Lancashire OL11 2PX
Tel: 01706 647422

Who fabricate the following:

Non-Rigid Fire Barriers

Type	Integrity (Mins)	Insulation (Mins)	Orientation
FIREFLY™ Apollo Lite	30	30	Vertical

have successfully completed the requirements of the SDP 21 Fire Rated Partition (inc Non Rigid Fire Barrier) scheme v2.3. This includes the fire testing of products to **BS 476: Part 22: 1987**, the inspection of their Factory Production Control and continuing surveillance assessments, and testing of samples of products taken from production. The product specification and field of application to achieve the performances as shown in the table above is detailed in the accompanying schedule: **IFCC1461/S01**

Initial Certification: 20 December 2018

Re-issued: 15 April 2024

Revised: 23 May 2025

Valid to: 19 December 2028

Issue number: 5

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

*This certificate consists of 1 page.
Publication of this certificate is permitted.*

