

Attestation

LEED v4, v4.1 BETA, and v5

On the 2nd of April 2025 Eurofins Product Testing A/S received a sample of a water-based coating with the product name:

FirePro CB Coating

supplied by

Rockwool Ltd.

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, and ISO 11890-2 testing standards (See test report no. 392-2025-00181003_A_EN and no. 392-2025-00181008_XG_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4, LEED v4.1 BETA (February 2024), and LEED v5 (April 2025) projects in Europe by showing compliance with the specifications for VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

- The requirements of LEED v4.1 BETA (February 2024) and LEED v5 (April 2025) by not exceeding the LCI values mentioned in the German AgBB Testing and Evaluation Scheme (2024), showing an overall R-value below or equal to 1 and having a TVOC according to EN 16516 below or equal to 1,000 µg/m³, a sum of VOC without LCI less than 100 µg/m³ and a formaldehyde emission below or equal to 10 µg/m³; all after 28 days.
- The requirements of LEED v4 by complying with:
 - The requirements of Indoor Air Comfort Gold version 9.0 (June 2023).

VOC content specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

- The requirements of LEED v4 and LEED v4.1 BETA (February 2024): EU Decopaint Directive 2004/42/CE for 'One-pack performance coating, WB' having a VOC content below 140 g/L.

16 July 2025



Claus Bonde
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.