

Attestation

LEED v4.1 BETA, and v5

On the 15th of July 2025 Eurofins Product Testing A/S received a sample of panel with the product name:

FirePro CB50 Coated Batt

supplied by

Rockwool Ltd.

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, and EN 16516 testing standards (See test report no. 392-2025-00181004_C_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (February 2024), and LEED v5 (April 2025) projects in Europe by showing compliance with the specifications for VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

- The requirements of LEED v4.1 BETA (February 2024) and LEED v5 (April 2025) by not exceeding the LCI values mentioned in the German AgBB Testing and Evaluation Scheme (2024), showing an overall R-value below or equal to 1 and having a TVOC according to EN 16516 below or equal to 1,000 µg/m³, a sum of VOC without LCI less than 100 µg/m³, and a formaldehyde emission below or equal to 10 µg/m³; all after 28 days.

21 August 2025



Claus Bonde
Analytical Service Manager



Isabella B. Larsen
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.