

# Attestation

## WELL Building Standard™

On the 2<sup>nd</sup> of April 2025, Eurofins Product Testing A/S received a sample of a joint sealant with the product name:

**FirePro AIS**

supplied by

**Rockwool Ltd.**

The sample was supplied as being representative of the manufactured product. sampling, testing, and evaluation were performed in accordance with the AgBB (2024)/EN 16516 (2017) with EU LCI VOC threshold values and ASTM D2369-20 test standards (See test report no. 392-2025-00181001\_A\_EN and 392-2025-00181006\_XG\_EN).

**The tested product complies with the requirements of WELL v2 Feature X06 VOC Restrictions: Part 1 by complying with:**

**VOC emissions specifications:**

- The requirements of AgBB (2024).

**VOC content specifications:**

- The requirement of SCAQMD Rule 1168 (Adhesives and sealants, 2022) for 'All other architectural sealants' having a VOC content below 50 g/L.

16 July 2025



Claus Bonde  
Analytical Service Manager



Rasmus Verdier  
Analytical Service Manager

*The International WELL Building Institute (IWBI) is a public benefit corporation whose mission is to improve human health and well-being in buildings and communities across the world through its WELL Building Standard (WELL). WELL™ and the related logo are trademarks owned by the IWBI and are used with permission.*